



Certificate of Performance



This certificate is awarded to **Profine India Window Technology Pvt Ltd.**
for the performance of **AluPure APSL-31mm Sliding System** of size **2700mm(W) x 2100mm(H)**
tested at our laboratory on **7th July 2018** as per **BS EN1026, BS EN1027 and BS EN12211.**
The classification of the tested sample is given below.

<i>Air Infiltration</i>	<u>Class 3</u>	(BS EN12207 : 2000)
<i>Static Water Penetration</i>	<u>Class 5A</u>	(BP EN12208 : 2000)
<i>Structural Performance</i>	<u>Class B5</u>	(BS EN12210 : 2000)


GOH AIK WEE
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.


CHIN YUN FEN
Managing Director