



Certificate of Performance




This certificate is awarded to Profine India Window Technology Pvt. Ltd.
for the performance of Alupure / Koemmerling – Majestic System of size 3.0 m (W) x 3.0 m (H)
tested at our laboratory on 25th Mar 2022 as per **BSEN Standards**.

The performance of the tested sample is given below.

AS PER BSEN STANDARD

Air permeability test as per **BS EN 1026, CLASS 3** as per **BE EN 12207**
Water penetration test as per **BS EN 1027, CLASS 7A** as per **BE EN 12208**
Wind load resistance test as per **BS EN 12211, CLASS BE₂₇₅₀** as per **BE EN 12210**



Detailed Performance Report No. : **WTIPL – 2022-32**

GOH AIK WEE
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.

CHIN YUN FEN
Managing Director