



Certificate of Performance



This certificate is awarded to Profine India Window Technology Pvt. Ltd.
for the performance of Alupure / Koemmerling APSL- 31mm Sliding System of size 2700 mm (W) x 2100 mm (H)
tested at our laboratory on 7th July 2018 as per **BS EN 1026, BS EN 1027, and BS EN 12211.**

The classification of the tested sample is given below.

Air permeability test **CLASS 3** as per (BS EN 12207: 2000)
Water penetration test **CLASS 5A** as per (BS EN 12208: 2000)
Wind load resistance test as per **CLASS B5** as per (BS EN 12210: 2000)

GOH AIK WEE
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.

CHIN YUN FEN
Managing Director