



# Certificate of Performance



This certificate is awarded to Profine India Window Technology Pvt. Ltd.  
for the performance of Alupure / Koemmerling APC - 46mm casement system of size 700 mm (W) x 1500 mm (H)  
tested at our laboratory on 7th July 2018 as per **BS EN 1026, BS EN 1027, and BS EN 12211.**

*The classification of the tested sample is given below.*

*Air permeability test* **CLASS 3** as per (BE EN 12207: 2000)  
*Water penetration test* **CLASS 7A** as per (BS EN 12208: 2000)  
*Wind load resistance test* as per **CLASS B5** as per (BS EN 12210: 2000)

A handwritten signature in blue ink, appearing to read 'Goh Aik Wee'.

**GOH AIK WEE**  
Director

**WINWALL TECHNOLOGY INDIA PRIVATE LTD.**

A handwritten signature in blue ink, appearing to read 'Chin Yun Fen'.

**CHIN YUN FEN**  
Managing Director