




Certificate of Performance



This certificate is awarded to Profine India Window Technology Pvt. Ltd.
for the performance of Alupure / Koemmerling – Majestic System of size 3.0 m (W) x 3.0 m (H)
tested at our laboratory on 25th Mar 2022 as per **BSEN Standards**.
The performance of the tested sample is given below.

AS PER BSEN STANDARD

Air permeability test as per BS EN 1026, **CLASS 3** as per BE EN 12207
Water penetration test as per BS EN 1027, **CLASS 7A** as per BE EN 12208
Wind load resistance test as per BS EN 12211, **CLASS BE₂₇₅₀** as per BE EN 12210



Detailed Performance Report No. : **WTIPL – 2022-32**


GOH AIK WEE
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.


CHIN YUN FEN
Managing Director