



# Certificate of Performance



This certificate is awarded to Profine India Window Technology Pvt. Ltd.  
for the performance of Alupure / Koemmerling - Opulenz Sliding Door of size 4 m (W) x 3 m (H)  
glass thickness DGU 35.52mm Thick (6mm + 1.52mm + 6mm Laminated Glass + 12mm Air gap + 10mm glass)  
tested at our laboratory on 5th March 2021 as per **BS EN Standards.**

The performance of the tested sample is given below.

## AS PER BS EN STANDARD

Air permeability test **CLASS 3** as per (BS EN 12207: 2016)

Water penetration test **CLASS 6A** as per (BS EN 12208: 2000)

Wind load resistance test as per **CLASS BE<sub>3000</sub>** as per (BS EN 12210: 2016)

Detailed Performance Report No. : **WINWALL IND - W0244A / 20 - 21**

  
**GOH AIK WEE**  
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.

  
**CHIN YUN FEN**  
Managing Director