



# Certificate of Performance



This certificate is awarded to Profine India Window Technology Pvt. Ltd.  
for the performance of Alupure / Koemmerling - Opulenz Sliding Door of size 4 m (W) x 4 m (H)  
glass thickness SGU 15.52mm Thick Thick (8mm + 1.52mm + 6mm Laminated Glass)  
tested at our laboratory on 4th March 2021 as per **BS EN Standards.**

The performance of the tested sample is given below.

## **AS PER BS EN STANDARD**

Air permeability test **CLASS 4** as per (BS EN 12207: 2016)

Water penetration test **CLASS 7A** as per (BS EN 12208: 2000)

Wind load resistance test as per **CLASS BE<sub>3000</sub>** as per (BS EN 12210: 2016)

**Detailed Performance Report No. : WINWALL IND - W0244 / 20 - 21**

**GOH AIK WEE**  
Director

**WINWALL TECHNOLOGY INDIA PRIVATE LTD.**

**CHIN YUN FEN**  
Managing Director